Bear Island Metal Roof Standards:

- 1. Panels must be of coated (painted) aluminum or Galvalume (steel), no textured surface
- 2. Panel must be painted with coating containing 70% KYNAR 500 PVDF resin, no texture.
- 3. Panel must be standing seam type
- 4. Panel must be either Snap lock or Mechanical lock
- 5. Panel width must be uniform, having a width of 14 to 18 inches.
- 6. Panels must be of striated type profile.
- 7. All panel fasteners (screws, bolts, clips) must be of stainless steel if using aluminum panels or Galvalume dipped/galvanized if using Galvalume panels and must be concealed.
- 8. Panels must be solid color, in white only.
- 9. Roof penetrations (e.g. exhaust vent caps, pipes, skylight trim) must be painted white to match the roof panel manufacturer's color.
- 10. Drip edge, trim, caps, edges and the like, must be the same material and color as roof panels.
- 11. Approved colors, if not listed below submit a sample.
- 12. All fasteners must be concealed including flashing at gables.

Mfr/Brand

ATAS	Ascot White		atas.com/colors
Berridge	Natural White		berridge.com/colors/
Drexel	Regal White		https://www.drexelmetalshome.com/wp-
content/uploads/2	2016/11/Residential	Color Chart.p	df

Englert Bone White roofing/metal-roof-panel-a1300

https://www.englertinc.com/metal-

Petersen/Pac-Clad Bone White availability-chart/

https://www.pac-clad.com/specs/color-

Ryerson/AlumaKlad Regal White

 Sheffield
 Regal White
 https://sheffieldmetals.com/wp

 content/uploads/2023/10/36627-Sheffield-Metals_WEBCARD.pdf
 Metals_WEBCARD.pdf

Metal Alliance	Regal White
Metal Sales	White & Polar White
Gulf Coast	Regal White & Solar White
Integrity Metals	Solar White & Regal White

Roofing Contractor confirms their installation will conform to the above standards:

Signature of Roofing Contractor